



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

ATM/F/IS Pressure Transmitter

IS / I, II, III / 1 / ABCDEFG; Entity; 10.00.0410
NI / I, II, III / 2 / ABCDFG; NIFW; 10.00.0410
Entity / Nonincendive field wiring parameters:
Vmax = 30 V, Imax = 100 mA, Pi = 1 W
Ci = 10 nF + 0.12 nF / meter of integral cable
Li = 0.1 mH + 0.001 mH / meter of integral cable

Temperature Class	T6	T4	T3
Ambient Range (°C)	-25 to +55	-25 to +85	-25 to +85
Process Range (°C)	-25 to +55	-25 to +100	-25 to +150

ATM/N/IS

IS / I, II, III / 1 / ABCDEFG; Entity; 10.00.0410
NI / I, II, III / 2 / ABCDFG; NIFW; 10.00.0410
Entity / Nonincendive field wiring parameters:
Vmax = 30 V, Imax = 100 mA, Pi = 1 W
Ci = 10 nF + 0.12 nF / meter of integral cable
Li = 0.1 mH + 0.001 mH / meter of integral cable

Temperature Class	T4
Ambient Range (°C)	-5 to +50
Process Range (°C)	-5 to +50

ATM/IS

IS / I, II, III / 1 / ABCDEFG; Entity; 10.00.0410
NI / I, II, III / 2 / ABCDFG; NIFW; 10.00.0410
Entity / Nonincendive field wiring parameters:
Vmax = 30 V, Imax = 100 mA, Pi = 1 W
Ci = 10 nF + 0.12 nF / meter of integral cable
Li = 0.1 mH + 0.001 mH / meter of integral cable

To verify the availability of the Approved product, please refer to www.approvalguide.com



Member of the FM Global Group

Temperature Class	T6	T4	T3
Ambient Range (°C)	-25 to +55	-25 to +85	-25 to +85
Process Range (°C)	-25 to +55	-25 to +100	-25 to +150

Equipment Ratings:

Intrinsically safe for Class I, II, III, Div 1, applicable Groups A, B, C, D, E, F, G; Nonincendive, using nonincendive field wiring parameters, for Class I, II, III, Division 2, applicable Groups A, B, C, D, F, G hazardous (classified) locations when installed per STS Drawing Number 10.00.0410. Ambient temperature ranges, process temperature ranges and temperature code ratings are as identified above.

FM Approved for:

STS Sensor Technik Sirmach AG
Ruetihofstrasse 8
CH 8370 Sirmach, Switzerland



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3610	2010
Class 3611	2004
Class 3810	2005

Original Project ID: 3027351

Approval Granted: July 18, 2007

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
080806	August 11, 2008		
090916	October 29, 2009		
131106	December 6, 2013		
140123	February 11, 2014		
RR204106	February 24, 2016		

FM Approvals LLC



J.E. Marquedant
Group Manager, Electrical

24 February 2016

Date